
The Power of an Energy Management system

Ali Omran


Asset Management Manager- CN



Mcgill University B.Eng Electrical Engineering 2014


Schneider Electric Advanced Technical Support. 2014-2017

- Joined CN Energy Management team 2017
- Leading CN Facilities Asset Management efforts since 2021



Agenda

- Benefits of real-time data to field staff
- Integration of EMIS data with enterprise BI tools
- Non-Energy benefits of EMIS systems
- Lessons learned from large developments



- the largest rail network in Canada and the only transcontinental network in North America.
- 19,600 route-miles of track in North America with three coasts Access
- transporting approximately C\$250 billion worth of goods annually:
 - Intermodal
 - Petroleum and chemicals
 - Grain and Fertilisers
 - Forest Products
 - Metals and Minerals
 - Automotive
 - Coal
 - And others



CN Energy in Numbers


- 25 Major Yard Monitored across North America
- Monitored Yearly Electrical Energy: 100 GWh (~9300 homes or YVR)
- Facilities: 2600 buildings and shops across CN network. Various equipment including: Compressors, switch heaters, Communications.
- Monitored Peak demand : 30 MW



A Typical Large Yard




Monitoring Infrastructure




Monitoring Infrastructure- Field Devices


1- Developed a Monitoring standard to streamline installations on existing infrastructure as well as new installations

2- The focus is on critical assets that can help the team from both the maintenance and energy management aspect .



Monitoring Infrastructure- Software Layers





Integration- Tableau based Energy dashboards



FM Asset Management


Building Level Cost Analysis: Multiple Cities Selected

Country All	City All	Building Type All	Sorting Method Utility	City Level	List Vi
State/Prov All	FCI Value All	Building Status All	Graph Value Sorted Field	5	1ର ୧

\$/Sq.ft	\$0.0			\$14.0						Sort by Total
© 2021	Mapbox © OpenStreetMap		and the second s						0K	500K
		A starter		2	MAC-ADM	Macmillan Administration A Building	Vaughan, ON	FM_BunkHouse	1	136,481
					EDM-FMS	Edmonton Walker Facility Maintenance Shop	Edmonton, AB	FM_Shop		140,000
		1 i h	wi"		EDM-HRC-CAR	Edmonton Walker HRC Car Shop Bldg	Edmonton, AB	FM_Shop		150,000
					TRA-CAR	Transcona Car Shop	Winnipeg, MB	FM_CarShop		156,228
					TAS-COM	Taschereau LRC Atelier Diesel	Montreal, QC	FM_LRC		163,182
					MEM-CAR	Memphis car shop	Memphis, TN	FM_CarShop		167,700
		Council B	Bluffs Shed 1		MEM-LRC	Memphis LRC	Memphis, TN	FM_LRC		171,600
	and the second sec	a Men 34			TRA-MOT	Transcona Motive Power Shop	Winnipeg, MB	FM_Shop		179,610
		CAR			TRA-WHE	Transcona wheel shop	Winnipeg, MB	FM_Shop		185,800
	1 28	Kale X-	*****		FDL-FBS	B - Shop (Car Repair)	North Fond Du Lac, WI	FM_CarShop		193,485
		The states	6 · · · · · ·		MEL-MEC	Melville Car Shop	Melville, SK	FM_CarShop		196,000
				ໍຸຈຸຈ	EDM-OPB	Walker Operations Building - B Building	Edmonton, AB	FM_Office		200,000
	တူး		0.0.0.8	1 Carren	FON-MEC	Building A	North Fond Du Lac, WI	FM_LRC		208,617
1	· · · ·			A MARKA	TRA-CAM	Transcona CN Campus	Winnipeg, MB	FM_Campus		221,240
	૾૾ૺ૾૾૽૾૽૽ૢૼૢ૾૾ૢૢૢૢૢૢૢૢૢૢૢૢૢૢૢૢૢૢૢૢૢૢૢૢૢૢ	200		47 - " " " "	MAC-ADB	Macmillan Administration B Building	Vaughan, ON	FM_Office		242,297
S S	°°°°°	•		Stand I have	TRA-POW	Transcona Power Plant	Winnipeg, MB	FM_Shed		246,398
12		0	the state) (and a later	SYM-LRC	Symington LRC	Winnipeg, MB	FM_LRC		252,350
	°. •				SAS-MEC	Saskatoon Mechanical Shop	Saskatoon, SK	FM_CarShop		270,000
25	Hay River Trans	portation Office			EDM-OPS	Walker Operations Building - A Building	Edmonton, AB	FM_Office		290,000
123725		11 11 11 11			HOM-ADM	Homewood Administration Bldg	Homewood, IL	FM_Office		300,000
4.2	AND CONTRACT	P. A. M.	· · · ·		PRI-LRC-RMO	Prince George SY Mechanical LRC	Prince George, BC	FM_LRC		414,000
				A Star A	BRA-055	Brampton 55 Devon Road	Brampton, ON	FM_Office		422,800
	N. S. Sandi				EDM-LRC	Walker - LRC	Edmonton, AB	FM_LRC		528,000
	\$/Sqft: \$6.41	\$R&M/Sqft: \$2.89	FCI >0.3: 572	DM: \$483.3M	MAC-LRC	Macmillan LRC	Vaughan, ON	FM_LRC		
Tota	al Cost: \$56.34M	\$Utilities/Sqft: \$1.94	FCI <0.3: 749	CRV: \$1,760.2M	WOO-LRC	Woodcrest LRC	Homewood, IL	FM_LRC		
Toto	al Sqft: 8,784,453	\$Janitorial/Sqft: \$1.58	Average FCI: 0.27	Building Count: 1,323	Utility of B	uilding Sorted By Utility c	ick on a building	to see survey		
					L					

Integration- Energy +Asset Management RETScreen Expert - Symington-LRC.retx


– 🗆 X



Integration-RETSCREEN

12

Example System: Compressed Air



Compressor Monitoring

Why is it important to monitor?


- Compressors consume between 15-30% of our electrical energy.
- Compressors are used to charge train cars and operate equipment and the system functionality is crucial for CN operations.
- Pressure must be maintained at a certain level.
- Avoid Excessive Airflow from the compressors.
- Verify compressor system work sequence



Compressor Monitoring

Monitor Pressure


Detect Leakage and high airflow




Ease of accessibility

1- Union staff have mobile access to monitor Compressors


Edmonton Intermodal



Compressor Incident- Vancouver



Example System: Snow Blower System




Switch heater Monitoring

- Switch Heaters/Blowers are crucial for Track operations in winter season
- They account for up to 40% of our winter demand
- A good candidate for automation and control given their weather dependability.





Yard Equipment monitoring (NEBs)



• Troubleshoot blower panels by looking at real-time current readings.


Buildings Monitoring

- Keep Track of Energy Usage and spot abnormalities in real time
- Track the short term demand and compare it to the long term demand.




Buildings Monitoring

• Spotting anomalies by comparing similar sized buildings within the same climate zone




Benchmarking

- 1- Group Buildings based on ASHRAE climate zone
- 2- Easy to compare building performance and establish benchmarks



Why do we need an energy model?

- Analyzing raw data can be tricky
- What drives energy usage in a facility?
- Comparisons can be misleading if the conditions are different (eg. colder winters).



Evolution of EMS



How it started

MacMillian Yard System Overview

MacMillian Yard (Total) : 1,565.2 kW	A
Langstaff Rd (Total) : 0.0 kW	A
Highway 7 (Total) : 1,565.2 kW	A
LRC - Diesel Shop (Total) : 565.8 kW	
Car Shop (Total) : 127.0 kW	
Adminstration Bldg (Total) : 324.7 kW	
Wheel Shop (Total) : 0.0 kW	
Maintenance Shop (Total) : 0.0 kW	
UnMetered (Total) : 547.8 kW	
LRC - Diesel Shop (Total) : 565.8 kW	
Main 1 (Total) : 324.1 kW	A
Main 2 (Total) : 240.5 kW	
Service Tracks (Total) : 169.3 kW	
LRC Natural Gas (Bldg) : 0 CuFt/Hr	
Nat Gas Costs (Month to Date) \$: 0.00	
Temp : 22.8 Celcius Wind : 25.0 - kM/Hr	
Wind Dir : 210 Deg S No Precipitation	

/			_
MacMillian	Yard (Total) : 1,7	789.8 kVA	
MacMilli	an Yard (Total) :	1,565.2 kW	
MacMilli	an Yard (Total) :	0.8745 PF	
MacMilli	an Yard (Total)*	: 27,338 Volts	
Ra	tes:\$/kW	Rates : \$/kWh	
Electrica	al Costs (Month to	o Date) \$:	
Administrat	ion Bldg (Total) :	: 324.7 kW	掘
Building	A (Total) : 72.3 k	w	占
Building	B (Total) : 252.6	k₩	桶
Natural (Gas (Bldg) : 0 Cu	ıFt/Hr	
Car Shop (1	Fotal) : 127.0 kW		掘
Natural (Gas (Bldg) : 0 Cu	iFt/Hr	
Compresse	d Air (Total Yard	i): kW	h
Compres	ssed Air (Total Y	'ard): SCFM	
L Yard - Co	mpressor (Total)) : 48.4 kW	層
Compres	ssed Air (Total) :	10 SCFM	
Compres	ssed Air (Total) :	127.0 PSIG	
Dryer (T	otal) : 0 kW		
West Yard ·	Compressor (T	otal) : 75.5 kW	掘
Compres	ssed Air (Total) :	21 SCFM	
Comprov		129 0810	
compres	ssed Air (Total) :	TJUFJIG	

W 400 500 500 200 200 500 500 500 500 500 5	MacMillian Yard [[otal] : 1,558 kW	
160044 180044 MacMillian Yard Compressed Air	200044 220044 Brampton Intermodal Compressed Air	00044 120044)
Local Yard - C1 - (Total) : 0.0 kW	North Yard - C1 - [Total] : kW	MacMillian Yard (Total) ; kW
Local Yard - C2 - (Total) : 26.3 kW	North Yard - (Total) : SCFM	Langstaff Rd (Total) : 0.0 kW
Local Yard - Dryer - (Total) : 0.0 kW	North Yard - (Total) : PSI	Highway 7 (Total) : 1,568.0 kW
Local Yard - (Total) : 7.7 SCFM	South Yard - C1 - (Total) : kW	LRC - Diesel Shop (Total) : kW
Local Yard - (Total) : 132.9 PSI	South Yard - (Total) : SCFM	Car Shop (Total) : 125.9 kW
West Yard - C1 - (Total) : 51.4 kW	South Yard - (Total) : PSI	Adminstration Bldg (Total): kW
West Yard - C2 - (Total) : 26.1 kW		MacMillian Yard (Total)* : 27,409 Volts
West Yard - Dryer - (Total) : 0.0 kW	Brampton Data Center	Brampton Intermodal (Total) : kW
West Yard - (Total) : 17.5 SCFM	Main Incoming - (Total) : kW	Main Incoming 1 (Total): kW
West Yard - (Total) : 138.1 PSI	Main Incoming - Vab : Volts	Main Incoming 2 · Refer (Total) : kW
East Yard - C1 - (Total) : kW	Main Incoming - Vbc : Volts	Maritime Ontario (Total) : 5.8 kW
East Yard - C2 - (Total) : kW	Main Incoming - Vca : Volts	Operations Bldg Vault - VII Avg : Volts
East Yard - Dryer - (Total) : kW	Main Incoming - la : Amps	North Gen Vault - VII Avg : Volts
East Yard - (Total) : SCFM	Main Incoming - Ib : Amps	Clark Street Vault - VII Avg : Volts
East Yard - (Total) : PSI	Main Incoming - Ic : Amps	In Gate Vault - VII Avg : Volts

PSI 0100	ver Pressure (PSI	1 Receiver) : 85 PSI	 	C Tow PSI 80 60 40 11:43:55		sure (PSI_	2 Regulated) : 1	
L Tow PSI 80 60 40 11:43:55	rer Pressure (PSI_	1 Receiver) : 91 PSI		L Tow PSI 80 60 40 11:43:55		sure (PSI_ 43:55	2 Regulated) : 1	
SCFM 3000 2000 1000 0.000 11:43:55		Total Yard		(SCFM) : 237 SCF	FM	55	21-43-55	
	ard Total KW (C1_	C2_C3) : 88 KW		C1 (L Tower) : 3	85 KW	C1 (Hours) : 33,122.4 Hrs	ay : 17.2 Hr
225 150 75	abaarteert.			C2 (C Tower) : 5			i) : 27,281.0 Hrs	
150	15:43:55	19:43:55		C2 (C Tower) : 5 C3 (C Tower) : 1			s) : 27,281.0 Hrs s) : 5,435.6 Hrs) ay : 23.2 Hr: Day : 0.3 Hrs
150 75 0 11:43:55 Amps 7.5 5.0 2.5	er Amps - L Tower	r (D1) : 0.00 Amps		C3 (C Tower) : SCFM L 600 400 200	0 kW	C3 (Hour: Flow (SC	s) : 5,435.6 Hrs FM) : 42 SCFM	
150 75 0 11 43 55 Amps Dry 7.5 5.0 2.5			 +	C3 (C Tower) : 1 SCFM L 600 400	0 kW	C3 (Hour	s) : 5,435.6 Hrs	
150 75 0 11:43:55 Amps 7.5 5.0 2.5	er Amps - L Tower 15:43:55 L Tower :	r (D1) : 0.00 Amps 19:43:55 35 %	 +	C3 (C Tower) : 1 SCFM L 400 200 11:43:55 SCFM C 600 400	0 KW L Tower	C3 (Hour Flow (SC 5:43:55	s) : 5,435.6 Hrs FM) : 42 SCFM	
150 75 0 11:43:55 Amps 7.5 5.0 2.5	er Amps - L Tower	r (D1) : 0.00 Amps 19:43:55 35 %	 + + + + + + + + + + + + +	C3 (C Tower) : 1 SCFM L 600 200 0 11:43:55 SCFM C 600	0 KW L Tower	C3 (Hour Flow (SC 5:43:55	s) : 5,435.6 Hrs FM) : 42 SCFM 19:43:55	

The Full story- Easy to read



26

Thank you!

CHINA SHIPPING

The State of

CHINA SHIPPING

and the second second of the second second

A STATE OF THE AND A STATE OF THE ASSAULT

20.2

REAL PROPERTY OF

CN

CN