



Power Quality Overview

Understanding power disturbance analysis, fault direction, signatures, EN50160, etc

Alec Rancourt, jr. eng.

Power Quality Sales Expert

Power Management Offer Portfolio

Measure

Gather accurate power and energy data from key distribution points, monitor power quality, log events



Interoperability
Standard Industry protocols and form factors
Customization: scalability in size and performance

Understand

Turn data into meaningful, actionable information for you and your stakeholders



Robust, flexible software platform architectures
Real-time energy consumption monitoring
Dynamic control interfaces
Real-time and historical power quality analysis

Act

Make timelier, intelligent decisions based on valid, actionable information



Increased energy efficiency and cost savings
Maximize electrical network reliability and availability
Optimize electrical asset performance












Different types of Power Quality problems: PQ Fundamentals

In most cases, your Electrical Energy provider provides you *almost* perfect Electrical Power.

This is characterized by:

- Nominal **Voltage** on all 3 phases
- Nominal **frequency** (60.00Hz)
- **Waveforms** are perfectly sinusoidal
- **Symmetry** in all phases

If either of these characteristics vary, we have an Electrical Power Quality problem

Disturbance category	Waveform	Effects	Possible causes
Transients		Equipment malfunction and damage	Lightning or switching of inductive / capacitive loads
Interruption		Downtime, equipment damage, loss of data possible	Utility faults, equipment failure, breaker tripping
Sag		Downtime, system halts, data loss	Utility or facility faults, startup of large motors
Swell		Equipment damage and reduced life	Utility faults, load changes
Undervoltage		Shutdown, malfunction, equipment failure	Load changes, overload, faults
Overvoltage		Equipment damage and reduced life	Load changes, faults, over compensation
Harmonics		Equipment damage and reduced life, nuisance breaker tripping, power losses	Electronic loads (non-linear loads)
Unbalance		Malfunction, motor damage	Unequal distribution of single phase loads
Voltage fluctuations		Light flicker and equipment malfunction	Load exhibiting significant current variations
Power frequency variations		Malfunction or motor degradation	Standby generators or poor power infrastructure
Power Factor *		Increased electricity bill, overload, power losses	Inductive loads (ex. motors, transformers...)

Voltage Problems – Basics

Chronic Voltage Problems


Voltage outside $\pm 10\%$ for > 60 seconds

Voltage Sag

Voltage $< 90\%$ for $\frac{1}{2}$ cycle to 1 minute

Interruption

Voltage $< 10\%$ for > 3 cycles



A Sub-Cycle problem

Effects of Harmonics

Different Perspectives

Engineering Perspective

- Nuisance tripping of circuit breaker
- Harmonic resonance
- Capacitor bank failure
- Excessive heating
- Transformer overheating
- Skin effects on cables for higher harmonic orders
- Motor winding burnt (dv/dt) & hunting
- Neutral overloading (double neutral)
- Causing EMI to sensitive signals
- Problems to generators


Business Perspective

- Increased maintenance and replacement cost (OPEX)
- Interruptions and downtimes cost
- Reduced system capacity and thus increase CAPEX by unnecessary of expansion.



PWM VFD without 3% Line Reactance

Current Distortion:

THDi \approx 90%





Basic PWM VSD



Harmonics: Fundamentals (cont.)

- Power source supplies the current the loads require for proper operation
- Harmonic current (I_h) is produced when an electrical device uses (draws) current in a non-sinusoidal manner
- The lower the harmonic order the higher the amplitude of the current





IEEE Standard 519-2014

Compliances, Updates, Solutions and Case Studies

Presented by: Dr John Cheng, CEng, CEM, CEA, CMVP

How to rate harmonics - IEEE 519

IEEE STD 519-2014

Table 2—Current distortion limits for systems rated 120 V through 69 kV

Maximum harmonic current distortion in percent of I_L						
Individual harmonic order (odd harmonics) ^{a,b}						
I_{sc}/I_L	$3 \leq h < 11$	$11 \leq h < 17$	$17 \leq h < 23$	$23 \leq h < 35$	$35 \leq h \leq 50$	TDD
$< 20^c$	4.0	2.0	1.5	0.6	0.3	5.0
$20 < 50$	7.0	3.5	2.5	1.0	0.5	8.0
$50 < 100$	10.0	4.5	4.0	1.5	0.7	12.0
$100 < 1000$	12.0	5.5	5.0	2.0	1.0	15.0
> 1000	15.0	7.0	6.0	2.5	1.4	20.0

^aEven harmonics are limited to 25% of the odd harmonic limits above.

^bCurrent distortions that result in a dc offset, e.g., half-wave converters, are not allowed.

^cAll power generation equipment is limited to these values of current distortion, regardless of actual I_{sc}/I_L

where

I_{sc} = maximum short-circuit current at PCC

I_L = maximum demand load current (fundamental frequency component)
at the PCC under normal load operating conditions

Table 1—Voltage distortion limits

Bus voltage V at PCC	Individual harmonic (%)	Total harmonic distortion THD (%)
$V \leq 1.0$ kV	5.0	8.0
1 kV $< V \leq 69$ kV	3.0	5.0
69 kV $< V \leq 161$ kV	1.5	2.5
161 kV $< V$	1.0	1.5 ^a


^aHigh-voltage systems can have up to 2.0% THD where the cause is an HVDC terminal whose effects will have attenuated at points in the network where future users may be connected.

Harmonic Mitigation Solutions

VSD with ...			VSD with Multi-pulse supply			Active Harmonic Filter	Active Front End VSD
no filter	Choke (3% Z)	passive Filter	12-p	18-p	24-p		
90-120% THDi	30...40% THDi	10...20% THDi	12...15% THDi	5...8% THDi	< 5% THDi	3% to 5% THDi	2% to 5% THDi

Figure 1 THDi levels achieved with various harmonic mitigation methods


AccuSine PCS+




This selection meets or exceeds the harmonic objective of	8.00%	THDi
This selection fails to meet the objective displacement PF [Cos ϕ] of	0.9500	DPF (Cos ϕ)

AccuSine PCS+ theory of operation

AccuSine PLUS is a power electronic converter utilizing digital logic to inject corrective currents into a 3-phase power-source. These injected currents will compensate for existing harmonic currents from the 2nd to the 50th harmonic order drawn by non-linear loads connected to that grid.



AccuSine PCS+ Demo Video



AccuSine PCSn – Single Phase Harmonic Mitigation

- Mitigating harmonic current for 3 phase AND neutral loads.
- Eliminating excess current in the neutral due to load imbalance.
- Correcting load imbalance and neutral harmonic current due to single phase non-linear loads.

Building segment



Commercial &
Office space



Retail
space



Healthcare



Hotel &
Casino




Life sciences
& University




Light
Industrial



Food &
Beverage



Different remedies for different Power Quality problems



Power System Audits



Investigation of specific problems with your power system



Complete audit including measurement, analysis and reporting of power quality



Recommendations for power quality improvement



Power Quality Audits

Case Studies

Life Is On



Case study 1: Active Harmonic Filter turnkey project, hospital application



The existing situation

The hospital's air conditioning system had recently been modernized with a fleet of Variable Speed Drives (VSDs). These VSDs were polluting the hospital's electrical network and were regularly causing the new dialysis machines to malfunction. Diabetic patients were regularly sent home and asked to reschedule their treatment. The hospital's management had visibility on this problem and were eager to find someone with the knowhow to solve the issues. Schneider Electric's senior Power Quality specialists pinpointed the source of the harmonic distortion to be VSDs which were installed throughout the facility to efficiently regulate airflow and air pressure. The harmonic current produced by the VSDs was interacting with distribution transformers throughout the hospital and creating Voltage Distortion. Schneider Electric provided a turnkey proposal to design and implement PQ mitigation within the hospital's facility.

The Solution



Turnkey design & installation proposal


We sold our ability provide a turnkey proposal to comprehensively analyze and mitigate the Power Quality problems afflicting the dialysis machines. These PQ problems were severely impacting the quality of patient care and inhibiting the hospital's ability to manage diabetic patient care.

Customer Profile

In late 2013 a mid-size hospital reported the malfunction of several dialysis machines which were significantly impacting the quality of patient care. Schneider Electric's PQ Engineer performed a first PQ Audit in January. This PQ Audit led to the sale of a **PME 7.2** (Power Monitoring Expert) Power Monitoring system which was utilized, in conjunction with a fleet of PM800 Meters, sold as part of the initial construction, to measure the harmonic current produced by VSDs added throughout the facility as part of an Energy Efficiency project.


Power Quality disturbances


- 1. Voltage Distortion (aka THDv or Vthd)
- 2. Voltage Sag
- 3. Multiple Zero crossings



POWER		VOLTAGE		CURRENT	
Freq	57.913 Hz				
P1	0.0473MVA	U1	116.46 V	I1	0.4268kA
P2	0.0611MVA	U2	115.84 V	I2	0.5341kA
P3	0.0521MVA	U3	115.70 V	I3	0.4640kA
Psum	0.1606MVA	THD-U1	3.25 %	THD-I1	10.12 %
S1	0.0497MVA	THD-U2	8.79 %	THD-I2	10.71 %
S2	0.0619MVA	THD-U3	7.41 %	THD-I3	12.48 %
S3	0.0537MVA	Upk+1	157.57 V	Ipk+1	0.616kA
Sum	0.1659MVA	Upk+2	163.26 V	Ipk+2	0.684kA
Q1	0.0152MVA	Upk+3	165.17 V	Ipk+3	0.752kA
Q2	0.0059MVA	Upk-1	-164.25 V	Ipk-1	-0.715kA
Q3	0.0128MVA	Upk-2	-160.14 V	Ipk-2	-0.641kA
Qsum	0.0379MVA	Upk-3	-169.61 V	Ipk-3	-0.758kA
PF-1	0.9523	Uave	116.01 V	KF1	1.17
PF-2	0.9677	Unb	0.95 %	KF2	1.24
PF-3	0.9711			KF3	1.30
PFsum	0.9716	Iave		Iunb	0.4756kA
				Iunb	7.62 %

POWER		VOLTAGE		CURRENT	
Freq	59.968 Hz				
P1	0.0728MVA	U1	119.09 V	I1	0.6229kA
P2	0.0872MVA	U2	120.17 V	I2	0.7300kA
P3	0.0717MVA	U3	120.51 V	I3	0.6069kA
Psum	0.2317MVA	THD-U1	4.78 %	THD-I1	7.94 %
S1	0.0741MVA	THD-U2	4.72 %	THD-I2	8.06 %
S2	0.0878MVA	THD-U3	4.70 %	THD-I3	8.51 %
S3	0.0730MVA	Upk+1	163.45 V	Ipk+1	0.901kA
Sum	0.2349MVA	Upk+2	163.61 V	Ipk+2	1.112kA
Q1	0.0139MVA	Upk+3	164.07 V	Ipk+3	0.939kA
Q2	0.0103MVA	Upk-1	-162.30 V	Ipk-1	-0.944kA
Q3	0.0137MVA	Upk-2	-162.93 V	Ipk-2	-1.120kA
Qsum	0.0379MVA	Upk-3	-163.74 V	Ipk-3	-0.940kA
PF1	0.9824	Uave	119.52 V	KF1	1.53
PF2	0.9930	Unb	0.90 %	KF2	1.47
PF3	0.9822			KF3	1.59
PFsum	0.9863	Iave		Iunb	0.6529kA
				Iunb	6.16 %





Schneider Electric offers a unique value proposal for Power Quality solutions

1. Investigate PQ problems anywhere in Canada
2. Diagnose and quantify problems onsite or remotely
3. Produce comprehensive engineering reports
4. Simulate network behavior as necessary
5. Design and deliver custom PQ mitigation solution
6. Validate performance
7. Support equipment through extended warranty and preventative maintenance

Pre-installation: Preliminary harmonic study

Voltage where AccuSine system is attached: 600 V

Point of Common Coupling (PCC) MCC Transformer - Secondary

Harmonic Standard for current limits is IEEE 519-2014 (optional)

Applied operational mode(s):

Harmonic Mitigation:	x	THDI Required:	
Power Factor Correction:	x	DPF (Cos ϕ) Required:	0.95
Percent of AccuSine PCS system assigned for Harmonic Mitigation:			

Equipment list for NONLINEAR LOADS

Item	Quantity	Size	Unit of Measure	Type of Equipment	Rectifier pulses	Installed Impedance (%Z)	Maximum Capacity Utilized	Full Load Displacement PF
1	3	75	HP	PWM VFD	6	3.00%	100.0%	
2	1	75	HP	PWM VFD	6	3.00%	50.0%	
3	1	15	HP	PWM VFD	6	3.00%	100.0%	
4	2	20	HP	PWM VFD	6	3.00%	100.0%	
5	1	5	HP	PWM VFD	6	3.00%	100.0%	
6	1	1.5	HP	PWM VFD	6	3.00%	100.0%	
7	1	30	HP	PWM VFD	6	3.00%	100.0%	
8								
9								
10								

AC Motors Operating Direct-on-Line

Item	Quantity	Size	Unit of Measure	Rated Full Load PF (Nameplate)	Maximum Capacity Utilized
11	1	41	HP	0.800	80.0%
12	1	45	HP	0.800	50.0%
13	1	52.48	HP	0.800	80.0%
14	1	2.5	HP	0.800	50.0%
15					

IEEE 519-2014 Table 2

$I_{sc}/I_{F,FLA}$	% TDD
<20	5%
<50	8%
<100	12%
<1000	15%
>=1000	20%

Equivalent installed impedance: 3.00%

Selection adjustment factor according to installed impedance: 1.20

System Short Circuit Ratio (ShCR) @ selected PCC: 39.8:1

Uncorrected System				
Type of RMS Current	Original System Current Amplitudes & Total Harmonic Current Distortion		Power	
Total I_{rms}	430.1	amps	447.02	KVA
Total I_{fund}	420.3	amps	402.43	KW

AccuSine+ rating required @ system bus voltage:	81.7	amps
---	------	------

AccuSine+ rating required @ unit base voltage:	81.7	amps
--	------	------


User Selected AccuSine+ rating @ unit base voltage:	94.0	amps
---	------	------

Corrected System				
Type of RMS Current	Corrected Current Amplitudes & Total Harmonic Current Distortion		Corrected Power	
Total I_{rms}	420.9	amps	437.41	KVA
Total I_{fund}	420.3	amps	402.43	KW
Total I_h	22.4	amps	0.9986	Distortion PF
Total $I_{reactive}$	141.1	amps	146.68	KVAR
% THDi (achieved)	5.33%		0.9395	Displacement PF
			0.9382	Total PF

(Displacement PF)

Case Study 2: Sawmill with Power Quality Meter

- Schneider Electric switchboard includes a PM8000 power quality meter
- Need for a power factor and harmonic study to size a capacitor bank and verify harmonics.
- PM8000 data downloaded in order to size equipment.



time	V	I	ab	mea	ll	ca	mea	ll	avg	mea	ll	unbal	mea	ll	to	MEAN	KVAR	TOT	lva	tot	mean	la	mean	lb	mean	lc	mean	l	avg	mea	ll	mean	pf	lead	lag	freq
15:00:0	464.8563	464.7993	465.9819	465.2125	0.165826	2.269	11	1,002.16	1,691.03	2,097.47	2,089.34	2,120.10	2,102.27	0	78.293788	60.004002	0.0000	463.7923	463.6493	464.9381	464.1266	0.174891	1,867.51	1,500.31	1,756.07	2,180.52	2,175.31	2,206.71	2,187.52	0	77.827225	60.05555	2.31954	0	78.679794	59.98609
30:00	480.7088	479.7509	481.5206	480.6601	0.200669	935.703477	782.9775	1,221.76	1,486.50	1,461.41	1,491.38	1,480.46	0	78.503852	60.00992	0.0000	480.0001	480.0002	487.5659	486.8817	0.169168	796.750201	609.9186	995.98242	1,191.52	1,176.25	1,192.28	1,184.02	0	78.903125	60.00294	1,882.02	0	76.237006	60.03032	
45:00	465.8876	465.7168	467.1001	466.2348	0.1836	1,321.23	1,087.86	1,712.29	2,125.20	2,105.37	2,119.99	2,123.52	0	77.140998	60.00769	0.0000	464.8081	465.0344	466.0502	465.2992	0.163713	1,364.05	1,110.07	1,759.58	2,178.21	2,177.80	2,203.34	2,186.45	0	77.676646	60.00887	2,153.74	0	77.960596	59.99043	
00:00	464.1263	464.0002	467.0905	466.4057	0.146887	1,340.37	1,104.33	1,737.52	2,150.27	2,145.56	2,165.40	2,153.90	0	77.960596	59.99043	0.0000	464.647	464.2646	465.5769	464.8295	0.162449	1,355.53	1,096.04	1,743.87	2,170.04	2,154.36	2,182.69	2,169.03	0	77.697021	60.00892	2,153.02	0	77.94001	60.0157	
15:00	464.884	464.5963	465.9525	465.1443	0.17796	1,348.10	1,084.35	1,731.02	2,149.12	2,138.58	2,168.66	2,152.12	0	77.828079	60.00707	0.0000	464.884	464.5963	465.9525	465.1443	0.17796	1,348.10	1,084.35	1,731.02	2,149.12	2,138.58	2,168.66	2,152.12	0	77.828079	60.00707	2,151.90	0	77.99404	59.99404	
30:00	467.9218	467.5555	468.9763	468.1512	0.176257	1,282.74	1,080.65	1,644.11	2,033.83	2,006.65	2,041.37	2,027.28	0	78.989276	60.02336	0.0000	467.9218	467.5555	468.9763	468.1512	0.176257	1,282.74	1,080.65	1,644.11	2,033.83	2,006.65	2,041.37	2,027.28	0	78.989276	60.02336	2,196.49	0	77.348832	60.01216	
45:00	466.6608	466.4288	467.6901	466.9265	0.163572	1,345.34	1,098.12	1,739.87	2,143.06	2,136.56	2,168.27	2,149.30	0	77.348832	60.01216	0.0000	466.6608	466.4288	467.6901	466.9265	0.163572	1,345.34	1,098.12	1,739.87	2,143.06	2,136.56	2,168.27	2,149.30	0	77.348832	60.01216	2,152.12	0	78.604263	60.026568	
00:00	464.9466	464.6229	465.9711	465.1791	0.170151	1,422.81	1,115.98	1,809.14	2,243.27	2,235.93	2,264.08	2,248.58	0	78.604263	60.026568	0.0000	464.9466	464.6229	465.9711	465.1791	0.170151	1,422.81	1,115.98	1,809.14	2,243.27	2,235.93	2,264.08	2,248.58	0	78.604263	60.026568	2,218.78	0	77.94812	60.01187	
15:00	466.9625	466.5112	467.9487	467.1402	0.173236	1,401.85	1,115.82	1,792.27	2,220.39	2,205.21	2,228.45	2,218.02	0	78.174995	59.99077	0.0000	466.9625	466.5112	467.9487	467.1402	0.173236	1,401.85	1,115.82	1,792.27	2,220.39	2,205.21	2,228.45	2,218.02	0	78.174995	59.99077	2,200.01	0	78.853392	59.98222	
30:00	469.8126	469.8801	471.1817	470.2868	0.186073	1,300.97	1,080.46	1,691.91	2,074.50	2,066.64	2,099.08	2,080.01	0	81.307922	59.97627	0.0000	469.8126	469.8801	471.1817	470.2868	0.186073	1,300.97	1,080.46	1,691.91	2,074.50	2,066.64	2,099.08	2,080.01	0	81.307922	59.97627	1,076.13	0	85.99274	59.97664	
45:00	494.4985	493.2502	496.0962	494.615	0.306739	885.192319	851.7685	775.58534	918.278	905.2935	910.9001	911.5106	0	89.225449	59.97718	0.0000	494.4985	493.2502	496.0962	494.615	0.306739	885.192319	851.7685	775.58534	918.278	905.2935	910.9001	911.5106	0	89.225449	59.97718	1,587.32	0	81.307922	59.97627	
00:00	501.5124	505.1343	508.740	507.1506	0.394656	385.853286	97.55667	410.975447	480.7441	464.8651	476.3375	475.6468	0	95.263298	59.97664	0.0000	501.5124	505.1343	508.740	507.1506	0.394656	385.853286	97.55667	410.975447	480.7441	464.8651	476.3375	475.6468	0	95.263298	59.97664	1,682.54	0	99.63765	59.98527	
15:00	508.8755	506.6937	510.3699	508.6404	0.388945	366.691437	16.8254	388.0871	434.849	410.7347	411.8501	422.4779	0	99.63765	59.98527	0.0000	508.8755	506.6937	510.3699	508.6404	0.388945	366.691437	16.8254	388.0871	434.849	410.7347	411.8501	422.4779	0	99.63765	59.98527	2,153.74	0	99.912469	59.97563	
45:00	510.1627	507.5304	511.7154	509.8028	0.446157	228.167633	-47.2608	234.33342	277.2282	255.3674	271.6693	268.0883	0	99.912469	59.97563	0.0000	510.1627	507.5304	511.7154	509.8028	0.446157	228.167633	-47.2608	234.33342	277.2282	255.3674	271.6693	268.0883	0	99.912469	59.97563	2,153.74	0	99.912469	59.97563	

Case Study 2: Sawmill with Power Quality Meter

- 700kVAR sized based highest recorded peak demand
- Low THDi & THDv


Existing P.F. (%)

Desired P.F. (%)

Load (kW)


Kilowatt Factor **0.450**

Required kVAR **664**



Case Study 3: Industry with PME

- Industries prone to
- Voltage sags symptoms:
 - Pharmaceutical
 - Hospitals
 - Electronics manufacturer
 - Water/waste water treatment plant
 - Food & Beverage



Worst Disturbance per Incident						
ID	Incident Time	Meter	Type	Phase	Duration (s)	Magnitude (%)
1	4/9/2018 2:49:48 PM	group1.Station_B001	Sag	V1	0.082	54.60
2	4/16/2018 12:50:30 AM	group1.Station_B001	Sag	V3	0.152	51.19
3	5/3/2018 5:15:01 AM	group1.Station_B001	Sag	V3	0.115	35.81
4	5/30/2018 12:01:13 PM	group1.Station_B001	Interruption	V1	5,461.043	0.00
5	6/2/2018 9:42:08 AM	group1.Station_B001	Sag	V3	0.016	89.90
6	6/4/2018 6:22:54 PM	group1.Station_B001	Sag	V2	0.026	81.07
7	6/13/2018 8:21:49 PM	group1.Station_B001	Interruption	V1	794.331	0.00
8	6/13/2018 10:56:18 PM	group1.Station_B001	Interruption	V1	624.286	0.00
9	6/24/2018 3:54:04 PM	group1.Station_B001	Sag	V1	0.009	87.68
10	7/2/2018 7:40:56 PM	group1.Station_B001	Sag	V1	0.150	86.16
11	7/4/2018 10:41:20 AM	group1.Station_B001	Sag	V3	0.083	81.16

Case Study 4: Commercial Building



Problem

- Commercial building busbars suffered from constant noise.
- Security threat, as resulting vibrations can lead to loosening connections.
- Source from single phase non-linear loads.

Solution

- Installation of 1 PCSn active harmonic filter to reduce harmonic distortion.
- Significantly lowered neutral current and eliminated noise.

THDi




Pic. 4 Harmonic spectrum – AccuSine stopped



Pic. 5 Harmonic spectrum – AccuSine running

Case Study 5: Municipality with PME

- Water/Waster treatment plant
- High harmonics detected
- Existing capacitor bank failing.



PQ Audit Case 6: Industry with Power Advisor

Potential Issue: Excessive Voltage Harmonic Distortion Condition



Meltshop.EM03A

Device Type: 7330

Threshold: 3.00% THD

System Load Affected: 2,127,700.04 %

Comment: Excessive Voltage Harmonic Distortion Condition has been found for multiple measurements at this location. The most severe is: Voltage Total Harmonic Distortion Mean on Input V1 reached 42.04%. This indicates significant voltage waveform distortion. It would be useful to include phase voltages and currents to be logged.

Measurement	Worst As %	Average	Minimum	Maximum	At Peak Demand
THD Voltage A-B mean	0.00 %	7.79%	0.00%	42.04%	---
THD Voltage C-A mean	0.00 %	7.80%	0.00%	41.43%	---
THD Voltage B-C mean	0.00 %	7.46%	0.00%	40.17%	---

Other Cases Studies

- Lighting retrofits
- Water/waste water treatment plants
- Cannabis
- VFD retrofits
- Small/mid size industries

Life Is On



Schneider
Electric



Case Study 7: Industry with ION7650

Large factory in Greater Toronto Area suffering from process line shut downs.

- Each time there is an unplanned shut down, system shuts down and powder coating spreads across the factories, requiring a thorough cleaning every time.
- Exiting ION meter installed by utility
- Study determined voltage sags and interruptions

Event #	Duration (s)	Magnitude Phase1	Magnitude Phase2	Magnitude Phase3	Event Type	# phases affected	SagFighter will correct ?	Flywheel UPS will ride through ?	Timestamp
1	0.767000	0%	0%	0%	Interuption	3	No	YES	09/07/2016 8:00:08.565 AM
2	0.000065	0%	0%	135%	Interuption	2	No	YES	09/05/2016 9:48:33.482 AM
3	0.000048	127%	0%	0%	Interuption	2	No	YES	09/04/2016 12:14:18.558 PM
4	0.000065	0%	130%	0%	Interuption	2	No	YES	09/03/2016 8:40:46.923 AM
5	0.000016	0%	0%	119%	Interuption	2	No	YES	09/01/2016 6:26:46.531 AM
6	0.000016	118%	0%	0%	Interuption	2	No	YES	8/27/2016 8:08:53.866 AM
7	0.083000	48%	46%	32%	Sag	3	YES	YES	8/26/2016 5:24:38.765 PM
8	0.900000	0%	0%	0%	Interuption	3	No	YES	08/07/2016 6:44:22.174 AM
9	0.880000	0%	0%	0%	Interuption	3	No	YES	7/29/2016 6:16:42.307 AM
10	0.941000	0%	0%	0%	Interuption	3	No	YES	07/03/2016 6:55:05.439 AM
11	0.925000	0%	0%	0%	Interuption	3	No	YES	07/01/2016 6:48:08.814 AM
12	0.109000	50%	49%	56%	Sag	3	YES	YES	6/24/2016 4:27:54.614 AM
13	0.867000	0%	0%	0%	Interuption	3	No	YES	5/30/2016 12:16:31.980 AM
14	0.033000	45%	47%	31%	Sag	3	YES	YES	5/29/2016 6:58:31.446 AM
15	0.000065	133%	0%	0%	Interuption	2	No	YES	5/23/2016 11:20:57.288 AM
16	0.075000	48%	53%	52%	Sag	3	YES	YES	5/17/2016 10:01:39.796 AM
17	0.125000	55%	48%	48%	Sag	3	YES	YES	05/06/2016 7:46:17.937 AM
18	0.000016	120%	0%	0%	Interuption	2	No	YES	05/01/2016 9:53:51.004 AM

Case Study 7: Industry with ION7650

Table 1 : Summary of financial impact of the Sag Fighter™ and Flywheel UPS solutions

	SagFighter™ Solution	Flywheel UPS Solution
Number of events covered by data	5	18
Number of weeks of data	18	18
Prorated estimated number of events per year	14.4	52.0
Average event cost	\$ 30,000	\$ 30,000
Yearly cost of events avoided	\$ 433,000	\$ 1,560,000
Estimated value of investment required for implementation of complete solution for all 10 process lines	\$ 1,593,000	\$ 2,484,000
Simple Payback in months	44	19
Simple Payback in years	3.68	1.59



	SagFighter™ Solution	Flywheel UPS Solution
Estimated value of investment required for implementation of a solution for one (1) process line	\$ 235,000	\$ 339,000

Old facilities: Power Factor Correction Opportunities


Electricity bills

Fixed capacitors should be removed.

Automatic capacitor banks: detuned & maintained.



Solution: Sag fighter and UPS



Draws extra current from the "healthy" phases to create an injection voltage

Figure 3 : SagFighter sketch





Figure 2 : positioning of the "Voltage Event Ride-Through System"


Voltage Power Quality Case Study: Sure Volt

- Pharmaceutical company with highly sensitive electronics.
- End of a utility line, suffering voltage drops during peak demand.
- Sensitive equipment goes offline, unplanned downtime




Data extracted from ION meter

- Lowest recorded voltage in past year: 75% of nominal voltage
- Recommended range: +-10% nominal voltage




Proposed solution: Sure-Volt

- 500kVA Sure-Volt proposed at artery where sensitive equipment is failing.
- Regulates voltage $\pm 3\%$



PQ Audit Case 3: Industry with PME


- Industries prone to
- Voltage sags symptoms:
 - Pharmaceutical
 - Hospitals
 - Electronics manufacturer
 - Water/waste water treatment plant



Worst Disturbance per Incident						
ID	Incident Time	Meter	Type	Phase	Duration (s)	Magnitude (%)
1	4/9/2018 2:49:48 PM	group1.Station_B001	Sag	V1	0.082	54.60
2	4/16/2018 12:50:30 AM	group1.Station_B001	Sag	V3	0.152	51.19
3	5/3/2018 5:15:01 AM	group1.Station_B001	Sag	V3	0.115	35.81
4	5/30/2018 12:01:13 PM	group1.Station_B001	Interruption	V1	5,461.043	0.00
5	6/2/2018 9:42:08 AM	group1.Station_B001	Sag	V3	0.016	89.90
6	6/4/2018 6:22:54 PM	group1.Station_B001	Sag	V2	0.026	81.07
7	6/13/2018 8:21:49 PM	group1.Station_B001	Interruption	V1	794.331	0.00
8	6/13/2018 10:56:18 PM	group1.Station_B001	Interruption	V1	624.286	0.00
9	6/24/2018 3:54:04 PM	group1.Station_B001	Sag	V1	0.009	87.68
10	7/2/2018 7:40:56 PM	group1.Station_B001	Sag	V1	0.150	86.16
11	7/4/2018 10:41:20 AM	group1.Station_B001	Sag	V3	0.083	81.16

Case 4: Municipality with PME

- Water/Waster treatment plant
- High harmonics
- Existing capacitor bank



PQ Audit Case 5: Large industry with Power Advisor

Potential Issue: Excessive Voltage Harmonic Distortion Condition



Meltshop.EM03A

Device Type: 7330

Threshold: 3.00% THD

System Load Affected: 2,127,700.04 %



Comment: Excessive Voltage Harmonic Distortion Condition has been found for multiple measurements at this location. The most severe is: Voltage Total Harmonic Distortion Mean on Input V1 reached 42.04%. This indicates significant voltage waveform distortion. It would be useful to include phase voltages and currents to be logged.

Measurement	Worst As %	Average	Minimum	Maximum	At Peak Demand
THD Voltage A-B mean	0.00 %	7.79%	0.00%	42.04%	---
THD Voltage C-A mean	0.00 %	7.80%	0.00%	41.43%	---
THD Voltage B-C mean	0.00 %	7.46%	0.00%	40.17%	---


Power Advisor



- **Simple, meaningful power system analytics**
 - Understand business impact of poor power quality
 - View cost impact from low power factor
 - Monitor the evolution of electrical system health



Power management with Power Quality Performance



Power Quality Performance



- **Simple, meaningful power system analytics**
 - Understand business impact of poor power quality
 - View cost impact from low power factor
 - Monitor the evolution of electrical system health

